

DEVICE

The mains powered M-Bus master LAN-WMBUS-MA is a plug-and-play Wired M-Bus to Wireless M-Bus converter to read out Wired M-Bus meters and transmit the data wirelessly using the Wireless M-Bus protocol. The device is mounted with an AC/DC-adaptor in combined enclosure.

ANTENNA

The repeater can either make use of two high performance internal antennas or one external antenna, depending on the model. To take advantage of both horizontal and vertical polarizations for maximum range while minimizing multipath problems. The antenna diversity is important to prevent losses due to different polarization, especially indoors.

Models with external SMA interface are suited when large antennas are desirable to cover larger areas or long distances.

STATUS MESSAGE

The device will, as default, on regular interval transmit a status message containing information of the current M-Bus load, number of connected meters, overloads, supported meters etc.

FIRMWARE

MODE	T1
READ OUT INTERVAL	Refer technical document
ENCRYPTION	Default AES128 encryption OMS 5. Profile A
MBUS DATA	Refer technical document

POWER/LIFETIME

POWER SUPPLY	230 VAC
RADIO	14 dBm (25mW) output power to antennas
ANTENNAS	Two antennas for true differential transmission or one external antenna
MAXIMUM LOADS	MA-4 16 mbus loads
	MA-8 16 mbus loads
	MA-16 16 mbus loads
	MA-64 32 mbus loads
	MA-128 32 mbus loads
	MA-500 32 mbus loads

GENERAL INFORMATION

STANDARDS	2014/53/EU (RED) EN 13757-3/4:2013, OMS 4.0.2 EN61000-6-2:2005 EN61000-6-1:2007
MATERIAL	RAL 9003 (signal white)
IP	67
SIZE (W x H x D)	150 x 150 x 53 mm
CONNECTOR	2 cable screw mount connectors
INDICATION LED	Power (green), TX (blue), RX (green), overload (red)

USAGE

When the device is powered up the device starts scanning the M-Bus for connected meters. It searches for secondary addresses on baudrate 2400 (other baudrate on request).

Each time a device is found, a short sound will be heard. After the scanning is completed, the device will make short sounds as many times as there are number of devices found. The maximum number of devices supported depends on the model. It is possible to trigger a new search by using a magnet and hold it by the reed contact where the label of the device is located.

The search takes about 5-10 minutes, depending on number of meters on the bus. After the search has been completed, the device will ask each meter every X minutes for new data and transmit the received data using the Wireless MBUS protocol using the long packet format (0x72). The device by default encrypts all payloads.



DEVICES

LAN-WMBUS-MA-4-A2	MBUS master 230V max 4 logical devices
LAN-WMBUS-MA-4-A2-X	MBUS master 230V max 4 logical devices with external antenna
LAN-WMBUS-MA-8-A2	MBUS master 230V max 8 logical devices
LAN-WMBUS-MA-8-A2-X	MBUS master 230V max 8 logical devices with external antenna
LAN-WMBUS-MA-16-A2	MBUS master 230V max 16 logical devices
LAN-WMBUS-MA-16-A2-X	MBUS master 230V max 16 logical devices with external antenna
LAN-WMBUS-MA-64-A2	MBUS master 230V max 64 logical devices
LAN-WMBUS-MA-64-A2-X	MBUS master 230V max 64 logical devices with external antenna
LAN-WMBUS-MA-128-A2	MBUS master 230V max 128 logical devices
LAN-WMBUS-MA-128-A2-X	MBUS master 230V max 128 logical devices with external antenna
LAN-WMBUS-MA-500-A2	MBUS master 230V max 500 logical devices
LAN-WMBUS-MA-500-A2-X	MBUS master 230V max 500 logical devices with external antenna

In addition to number of devices supported, some more parameters are configurable at purchase as below. For more details, see our documents (wM-Bus data format/Technical information/Configuration of device) on our webpage.

A = Alternative addressing used

E = No Encryption

S = No "Status message"

T = Do not Transmit empty packet if no response from meter

N = Do not search for New meters every 48 hours

F = Indication if no meter is Found during startup (constant beep until meter is found)

R = Increased Readout speed

EXAMPLE: LAN-WMBUS-MA-4-X-AEN

- Device support 4 logical meters
- Device has external antenna interface
- Alternative addressing is used
- Encryption is not used
- Device does not search for new meter

For more details, refer to our documents below found on our webpage:
wM-Bus data format / Technical information / Configuration of device